

# INTERIM LETTER OF AUTHORIZATION NR. 3724



This is to certify that <sup>(1)</sup> <sup>(2)</sup> <sup>(3)</sup>

**Vergokan, Oudenaarde, Belgium**

is hereby authorized<sup>1</sup> to act as

**Manufacturer**

in accordance with the applicable rules of

**10CFR50 Appendix B**

This authorization is granted on the basis of their Quality Assurance Manual "Kwaliteitshandboek"; Doc N°: KHB; Datum: 25.01.2017; Editie: 2 which scope and implementation have been reviewed and conditionally accepted by Electrabel on September 21<sup>st</sup> and 22<sup>nd</sup> 2017 (see audit report EBL ref. 10010720360/000/00 [ref. TE CNT-KCD/4FR/25825/000/00])

for the design, procurement, manufacturing, examination, testing, handling, packaging, storage, shipping of

**Cable support systems and accessories (see details overleaf)**

at the above location only, from September 26<sup>th</sup> 2017 until April 1<sup>st</sup> 2018.

<sup>1</sup>This authorization is subject to the holder's agreement to achieve the implementation of his Quality Assurance program and to have it reviewed and accepted by Tractebel prior to the expiration date of his Interim Letter, and prior to the issuance of a Certificate of Authorization.

**D. Couplet**  
Group Manager  
Nuclear Department

**Ch. Pierlot**  
General Manager  
Nuclear Department



AM-80-E | AUTHORI/4AC/3724 | CQR: 17060 | RSQ: NA

- (1) This authorization does not relieve its holder from his contractual obligations towards the Owner. By this authorization, Tractebel does not "approve", "certify", "rate", or "endorse" any product or construction.
- (2) In case of any change to the scope, performance address, company name, or any change in company organization or shareholding; the authorization document is deemed to be obsolete and will need renewal.
- (3) Acting for the benefit of Electrabel

### <sup>1</sup> Chemins de câbles

- KBS 35/60/85/110, en prenant l'épaisseur max pour une largeur donnée + accessoires associés (éclisse à boulonner, cloison de séparation, couvercle, etc.)

### Echelles à câbles

- KL 60 + accessoires associés (étrier de console, éclisse à boulonner, cloison de séparation, couvercle, etc.)
- HDKS 60 + accessoires associés (étrier de console, éclisse, cloison de séparation, couvercle, etc.)
- Attaches pour câbles

### Systemes de montage

- Console HDWK pour montage sur pendard/support
- Console HDWKM pour montage sur pendard/support (HDWKM 100-1000) ou fixation directe au mur (limité aux HDWKM 300-1000 en attente d'infos complémentaires sur les HDWKM 100-200)
- Console HDWKMD pour montage sur pendard/support ou fixation directe au mur
- Console HDHKI pour montage sur profilé IPN 80 ou IPE 80 en faisant une adaptation pour avoir 2 pts de fixation
- Console HDHKIZ pour montage sur profilé IPN 80 ou IPE 80
- Pendard HDHSIZ
- Profil HDIPE80S
- Plaque de tête HDIPL08 pour HDIPE80S pour fixation sol/plafond ou en pendard avec bracon
- Plaque de tête HDIPL10 pour HDIPE80S pour fixation sol/plafond ou en pendard avec bracon
- Rail de montage HDMP 41.41 pour les faibles masses (par exemple, fixation de tubes à câbles ou de goulottes à câbles de max 150 mm de large)

Attention au diamètre des perçages de la plaque de tête des consoles HDWKM et HDWKMD = 13mm. Une cheville HILTI HSL-3 M8 requiert 14mm, une M10 17mm. Il faudra vraisemblablement élargir les trous.

### Remarques

- Tous les produits seront en acier galvanisé à chaud ou, selon la disponibilité et la nécessité, en acier inox.
- Le fait de donner une liste de produits acceptables ne dispense pas de réaliser une vérification de la tenue sismique des fixations et ancrages au béton au cas par cas.

(1) This authorization does not relieve its holder from his contractual obligations towards the Owner. By this authorization, Tractebel does not "approve", "certify", "rate", or "endorse" any product or construction.  
 (2) In case of any change to the scope, performance address, company name, or any change in company organization or shareholding; the authorization document is deemed to be obsolete and will need renewal.  
 (3) Acting for the benefit of Electrabel