

# CERTIFICATE OF AUTHORIZATION NR. 3295 REVISION 01

This is to certify that <sup>(1)</sup> <sup>(2)</sup> <sup>(3)</sup>

## **VERGOKAN NV in Oudenaarde in Belgium**

is hereby authorized to act as **Manufacturer**  
in accordance with the applicable rules of **10CFR50 Appendix B**


This authorization is granted on the basis of their "Kwaliteitsmanagementsysteem" N°PRO editie 11 (13/12/2012) which scope and implementation have been reviewed and conditionally accepted by Electrabel on September 26<sup>th</sup>, 2014 (see audit report ref. EBL 10010497725/000/00 [ref. TE no. 14/054 - CNT-KCD/4FR/20877/000/00] & finally accepted on September 16<sup>th</sup>, 2015 (see audit report ref. EBL 10010497725/000/02 dated April 2017 [ref. TE no. 14/054 - CNT-KCD/4FR/20877/000/02])

for the design, procurement, manufacturing, examination, testing, handling, packaging, storage and shipping of

### **Cable support systems and accessories\***

(\*) see details overleaf

at the above location only from September 16<sup>th</sup>, 2015 until September 25<sup>th</sup>, 2017



**Damien COUPLET**  
Group Manager  
Nuclear Department



**Christian PIERLOT**  
General Manager  
Nuclear Department

(1) This authorization does not relieve its holder from his contractual obligations towards the Owner. By this authorization, Tractebel does not "approve", "certify", "test", or "endorse" any product or construction.  
(2) In case of any change to the scope, performance address, company name, or any change in company organization or shareholding, the authorization document is deemed to be obsolete and will need renewal.  
(3) Acting for the benefit of Electrabel

### Chemins de câbles

- KBS 35/60/85/110 en prenant l'épaisseur max pour une largeur donnée + accessoires associés (éclisse à boulonner, cloison de séparation, couvercle, etc.)

### Echelles à câbles

- KL 60 + accessoires associés (étrier de console, éclisse à boulonner, cloison de séparation, couvercle, etc.)
- HDKS 60 + accessoires associés (étrier de console, éclisse, cloison de séparation, couvercle, etc.)
- Attaches pour câbles

### Systèmes de montage

- Console HDWK pour montage sur pendard/support
- Console HDWKM pour montage sur pendard/support (HDWKM 100-1000) ou fixation directe au mur (HDWKM 300-1000, évaluation au cas par cas pour HDWKM 100-200)
- Console HDWKMD pour montage sur pendard/support ou fixation directe au mur
- Console HDHKI pour montage sur profilé IPN 80 ou IPE 80 en faisant une adaptation pour avoir 2 points de fixation
- Console HDHKIZ pour montage sur profilé IPN 80 ou IPE 80
- Pendard HDHSIZ
- Profil HDIPE80S
- Plaque de tête HDIPL 06 pour HDIPE80S pour fixation sol/plafond ou en pendard avec bracon
- Plaque de tête HDIPL 10 pour HDIPE80S pour fixation sol/plafond ou en pendard avec bracon
- Rail de montage HDMP 41.41 pour les faibles masses (fixation de tubes à câbles ou de goulottes à câbles de max 150 mm de large)

Attention au diamètre des perçages de la plaque de tête des consoles HDWKM et HDWKMD = 13 mm. Une cheville HILTI HSL-3 M8 requiert 14 mm, une M10 17 mm... Il faudra vraisemblablement élargir les trous.

### Remarques

- Tous les produits seront en acier galvanisé à chaud ou, selon la disponibilité et la nécessité, en acier inox.
- Le fait de donner une liste de produits acceptables ne dispense pas de réaliser une vérification de la tenue sismique des fixations et ancrages au béton au cas par cas.

(1) This authorization does not relieve its holder from his contractual obligations towards the Owner. By this authorization, Tractebel does not "approve", "certify", "rate", or "endorse" any product or construction.  
 (2) In case of any change to the scope, performance address, company name, or any change in company organization or shareholding, the authorization document is deemed to be obsolete and will need renewal.  
 (3) Acting for the benefit of Electrabel