



Meersbloem-Melden 16
 9700 Oudenaarde - Belgium
 Office + 32 55 31 83 35
 Web atkore.com/vergokan

ELECTRICAL CONTINUITY DECLARATION

Producer:	VERGOKAN NV
Reportname:	KBSCL35.---.075
Product description:	Cable tray clickable
Devices under test : (Productreferences)	KBSCL35.075.075
Test according to:	§ 11.1.2 of the IEC 61537
Description of testmethode:	A current of 25 A ± 1A A.C. having a frequency of 50 Hz to 60 Hz supplied by a source with a no-load voltage not exceeding 12 V shall be passed through the length of the samples. The voltage drop shall be measured between two points 50 mm each side of the coupler or integral coupling and again between two points 500 mm apart on one side of the joint. The impedances shall not exceed 50 mΩ across the joint and 5 mΩ per meter without the joint.
Manufactured by:	VERGOKAN N.V.
Test device:	HYAMP III 3130
Calibration certificate number:	130624-3130_9352036

[Declaration] :

We declare that above mentioned products are tested by VERGOKAN according to § 11.1.2 of the IEC 61537.

DESCRIPTION OF TEST:

Test number	Setup	Measuring points	Criteria to pass the test
1	Two cable trays KBSCL35.075.075 coupled with click only	On both trays 50mm of the coupling.	Impedance can not exceed 50mΩ

RESULTS OF TEST:

Test number	Test	Impedance	Result
1	1	1 mΩ	Pass
	2	1 mΩ	Pass
	3	2 mΩ	Pass
	4	1 mΩ	Pass

CONCLUSION:

All the devices under test where tested as described above and did meet their criteria to pass the test. **We can state that the cable tray KBSCL35.---.075 is conform to § 11.1.2 of the IEC 61537.**

Oudenaarde, May 8th 2026

Gino Declercq
Managing Director Vergokan



[Handwritten signature]

On condition that the product(s) is/are used in the manner intended and/or in accordance with the current installation standards and/or with the manufacturer's recommendations.

