

Meersbloem-Melden 16 9700 Oudenaarde - Belgium

Office + 32 55 31 83 35

Web

atkore.com/vergokan

## **ELECTRICAL CONTINUITY DECLARATION**

Producer:	VERGOKAN NV	
Reportname:	HDKS60	
Product description:	Cable ladder DAVID	
Devices under test :	HDKS60.200	
(Productreferences)	HDKS60.600	
	HDSSU	
Test according to:	§ 11.1.2 of the IEC 61537	
Description of testmethode:	A current of 25 A $\pm$ 1A A.C. having a frequency of 50 Hz to 60 Hz supplied by a source with a no-load voltage not exceeding 12 V shall be passed through the length of the samples. The voltage drop shall be measured between two points 50 mm each side of the coupler or integral coupling and again between two points 500 mm apart on one side of the joint. The impedances shall not exceed 50 m $\Omega$ across the joint and 5 m $\Omega$ per meter without the joint.	
Manufactured by:	VERGOKAN N.V.	
Test device:	HYAMP III 3130	
Calibration certificate number:	130624-3130_9352036	

[Declaration]:

We declare that above mentioned products are tested by VERGOKAN according to § 11.1.2 of the IEC 61537.

## **DESCRIPTION OF TEST:**

Test number	Setup	Measuring points	Criteria to pass the test
1	Two cable ladders HDKS60.200 coupled with HDSSU	On both trays 50mm of the coupling.	Impedance can not exceed $50 m\Omega$
2	Two cable ladders HDKS60.600 coupled with HDSSU	On both tray's 50mm of the coupling.	Impedance can not exceed $50 m\Omega$
3	HDKS60.200	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m
4	HDKS60.600	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m

## **RESULTS OF TEST:** (test performed November 12, 2013)

Test number	Test	Impedance	Result
1	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
2	1	3 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
3	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
4	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	1 mΩ	Pass
	3	2 mΩ	Pass
	2	1 mΩ	Pass
	3	1 mΩ	Pass
	3	1 mΩ	Pass

## **CONCLUSION:**

All the devices under test where tested as described above and did meet their criteria to pass the test. We can state that the cable ladder HDKS60.---is conform to § 11.1.2 of the IEC 61537.

Oudenaarde, april 5, 2023

Gino Declercq Managing Director Meerbloem Melden 16 9700 Oudenaarde VAT BE 0422 878 131 Reg Oud. 26 920

On condition that the product(s) is/are used in the manner intended and/or in accordance with the current installation standards and/or with the manufacturer's recommendations.

