

VERGOKAN NV
Meersbloem Melden 16, 9700 Oudenaarde - Belgium
T: + 32 55 31 83 35, F: + 32 55 31 43 88
www.vergokan.com

ELECTRICAL CONTINUITY DECLARATION

Producer:	VERGOKAN NV		
Reportname:	KBSM(I) 60**		
Product description:	Cable tray machine construction interlocking ends		
Devicesunder test :	KBSM 60*050*1.00		
(Productreferences)	KBSMI 60*075*1.00		
	KBSMI 60*300*1.00		
	KBV		
	VM 6*10		
	V 60*200		
Test according to:	§ 11.1.2 of the IEC 61537		
Description of testmethode:	ription of testmethode: A current of 25 A \pm 1A A.C. having a frequency of 50 Hz to 60 I supplied by a source with a no-load voltage not exceeding 12 \ shall be passed hrough the length of the samples. The voltage shall be measured between two points 50 mm each side of the coupler or integral coupling and again between two points 500 apart on one side of the joint. The impedances shall not exceed m Ω across the joint and 5 m Ω per meter without the joint.		
Manufactured by:	VERGOKAN N.V.		
Test device:	HYAMP III 3130		
Calibration certificate number:	130624-3130_9352036		

[Declaration]:

We declare that above mentioned products are tested by VERGOKAN according to § 11.1.2 of the IEC 61537.





VERGOKAN NV Meersbloem Melden 16, 9700 Oudenaarde - Belgium T: + 32 55 31 83 35, F: + 32 55 31 43 88 www.vergokan.com

DESCRIPTION OF TEST:

Test number	Setup	Measuring points	Criteria to pass the test
1	Two cable trays KBSM 60*050*1.00 coupled with V60*200 and VM 6*10	On both trays 50mm of the coupling.	Impedance can not exceed 50mΩ
2	Two cable trays KBSMI 60*075*1.00 coupled with VM 6*10	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
3	Two cable trays KBSMI 60*075*1.00 coupled with KBV	On both trays 50mm of the coupling.	Impedance can not exceed 50mΩ
4	Two cable trays KBSMI 60*300*1.00 coupled with VM 6*10	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
5	Two cable trays KBSMI 60*300*1.00 coupled with KBV	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
6	KBSM 60*050*1.00	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m
7	KBSMI 60*0.75*1.00	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m
8	KBSMI 60*300*1.00	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m

RESULTS OF TEST:

Test number	Test	Impedance	Result
1	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
2	1	1 mΩ	Pass
	2	1 mΩ	Pass
	3	1 mΩ	Pass
3	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
	1	2 mΩ	Pass
4	2	2 mΩ	Pass
	3	2 mΩ	Pass
5	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
6	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	3 mΩ	Pass
7	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
	1	2 mΩ	Pass
8	2	2 mΩ	Pass
	3	2mΩ	Pass





VERGOKAN NV Meersbloem Melden 16, 9700 Oudenaarde - Belgium T: + 32 55 31 83 35, F: + 32 55 31 43 88 www.vergokan.com

CONCLUSION:

All the devices under test where tested as described above and did meet their criteria to pass the test.

We can state that the cable tray KBSM(I) 60*---*-- is conform to

§ 11.1.2 of the IEC 61537.

Meerbloem Melden 16
7 9700 Oudenaarde 47
VAT BE 0422 878 131
Reg Oud. 26 920

Thomas Leus Operations Director

Oudenaarde, 12/11/2013

* Pictures of the test setup canbe obtained n request

On condition that the product(s) is/are used in the manner intended and/or in accordance with the current installation standards and/or with the manufacturer's recommendations.