

FUNCTION IN FIRE EXPERT JUDGEMENT REPORT WITH CLASSIFICATION FIRES-JR-053-16-NURE

Cable bearing system VERGOKAN with cables PRYSMIAN and PRAKAB

This is an electronic version of a classification report which was made as a copy of classification report officially issued in a paper form. The electronic version of a classification report shall be used only for informative purpose. Any information listed in this classification report is the property of the sponsor and shall not be used or published without written permission. Contents of this file may only be modified by the editor i.e. FIRES, s.r.o., Batizovce. Sponsor is allowed to publish this classification report in parts only with written permission of the editor.

FUNCTION IN FIRE EXPERT JUDGEMENT REPORT WITH CLASSIFICATION IN ACCORDANCE WITH ZP-27/2008

FIRES-JR-053-16-NURE

Name of the product: Cable bearing system VERGOKAN with cables PRYSMIAN and PRAKAB

Sponsor: VERGOKAN
Meersbloem Melden 16
9700 Oudenaarde
Belgium

Prepared by: FIRES, s.r.o.
Approved Body No. SK01
Osloboditeľov 282
059 35 Batizovce
Slovak Republic

Task No.: PR-16-0102

Date of issue: 14. 06. 2016

Reports: 3
Copy No.: 2

Distribution list:

Copy No. 1	FIRES, s. r. o., Osloboditeľov 282, 059 35 Batizovce, Slovak Republic (electronic version)
Copy No. 2	VERGOKAN, Meersbloem Melden 16, 9700 Oudenaarde, Belgium (electronic version)
Copy No. 3	VERGOKAN, Meersbloem Melden 16, 9700 Oudenaarde, Belgium

This expert judgement report consists of 7 pages and 13 annexes and may only be used or reproduced in its entirety.



1. INTRODUCTION

This expert judgement report with classification defines the function in fire classification assigned to element „Cable bearing system VERGOKAN with cables PRYSMIAN and PRAKAB” in accordance with the classes given in ZP-27/2008.

This expert judgement report defines field of application which is outside the field of direct application according test standard or outside the field of extended application according to relevant extended application standard. This expert judgement expresses the opinion of the FIRES and is based on the experience or internal rules of FIRES.

This products have already been classified by FIRES, s.r.o. and number of previous fire resistance expert judgement report with classification is FIRES-JR-038-11-NURE Issue 2, issued on 14. 12. 2011 with validity until 06. 07. 2016. Document FIRES-JR-053-16-NURE replaces expert judgement report with classification FIRES-JR-038-11-NURE Issue 2.

2. DETAILS OF CLASSIFIED PRODUCT

2.1 GENERAL

The element, Cable bearing system VERGOKAN with cables PRYSMIAN and PRAKAB, is defined as a cable bearing system for power and communication halogen free cables with circuit integrity maintenance in fire.

2.2 PRODUCT DESCRIPTION

The element comprise of cable bearing system VERGOKAN – cable trays with accessories (consoles, brackets, screws etc.) with power and communication halogen free cables PRYSMIAN and PRAKAB with circuit integrity maintenance in fire.

Cable trays KBSI

Cable trays are made of steel sheet 1,0 mm thick. Height of side wall is 60 mm. Width of tray is 400 mm. The trays are perforated on the sides and on the bottom. Cable tray is equipped with integrated junction. Trays are jointed together with 5 pcs of screws VMK 6x10 (new trademark is VMK6.10). Maximum load of trays is 20 kg.m⁻¹. Tested trays were KBSI 60x400x1,00 (new trademark is KBSI60.400.100).

Brackets WKM

Brackets are made of steel sheet 2,5 mm thick. Dimensions of the base steel sheet is (70x175) mm and 8,0 mm thick and is equipped by holes for installation. Holes for installation of trays are in upper part of the brackets.

Tested brackets were WKM 400 (new trademark is HDWKM400).

Consoles HSMU

Consoles are made from steel sheet and are composed of a head plate and the U 50 profile. Dimensions of the base head is (123x123) mm and 4,0 mm thick or (135x135) mm and 5,0 mm thick and is equipped by holes for installation. Dimensions of the U profile is (50x50) mm and 2,5 mm thick and is equipped by holes for installation of brackets. Tested consoles were HSMU 50x1000 (new trademark is HDHSMU50.1000).

SPACER TSU50 and HDTSU50

Spacers are made of steel sheet 1,0 mm thick (TSU50) or 1,5 mm thick (HDTSU50).

Cables

Power and communication free halogen cables are specified for stationary distribution of electrical energy in dry and damp premises. Since they are free from halogens and exhibit enhanced fire performance, these cables are used in those applications where in the event of fire, the negative effect on concentrations of people and valuable material goods must be minimized. Suitable for hotels, hospitals, underground railways, airport etc. to protect people and technical building equipment in the event of fire where there is requirement for maintaining the functional integrity all cable installation in the event of fire. The cables develop in case of fire low heat released rate and smoke and no burning particles drop away



during fire accident. Functional integrity all cable installation in the event of fire is guaranteed only with use specified supporting member and cables grips.

Used cables by test:

PRYSMIAN cables (producer Prysmian, Viale Sarca 222, IT-20126 Milano, Italy)

- cable (N)HXH-J E30 4x50 RM (2x);
- cable (N)HXH-J E30 4x1,5 RE (2x);
- cable (N)HXCH E30 4x50 RM/25 (2x);
- cable (N)HXCH E30 4x1,5 RE/1,5 (2x);
- cable (N)HXHX-J E90 4x50 RM (2x);
- cable (N)HXHX-J E90 4x1,5 RE (2x);
- cable (N)HXCHX E90 4x50 RM/25 (2x);
- cable (N)HXCHX E90 4x2,5 RE/2,5 (2x);
- cable JE-H(St)H E30 2x2x0,8 (2x).

PRAKAB cables (producer PRAKAB PRAŽSKÁ KABELOVNA, s.r.o., Ke Kablu 278, 102 09 Praha 15, Czech Republic)

- cable (N)HXH FE180 E90 4x50 RM (2x);
- cable (N)HXH FE180 E90 4x1,5 RE (2x);
- cable (N)HXCH FE180 E30 4x50 RM/25 (2x);
- cable (N)HXCH FE180 E30 4x1,5 RE/1,5 (2x);
- cable (N)HXH FE180 E30 4x50 RM (2x);
- cable (N)HXH FE180 E30 4x1,5 RE (2x);
- cable (N)HXCH FE180 E90 4x50 RM/25 (2x);
- cable (N)HXCH FE180 E90 4x1,5 RE/1,5 (2x);
- cable JE-H(St)H FE180 E90 2x2x0,8 (2x).

The length of supporting constructions and cables was 5,5 m, 4 m from that was exposed to fire. Power and communication cables were fixed to the steel sheet trays in the points of allowed bending radius by steel clamps according to the cable diameter.

More detailed information about product construction is shown in the drawings which form an integral part of test report [1]. Drawings were delivered by sponsor.

3. TEST REPORTS AND EXTENDED APPLICATION REPORTS IN SUPPORT OF CLASSIFICATION

3.1 TEST REPORTS AND EXTENDED APPLICATION REPORTS

No.	Name of laboratory	Name of sponsors	Test report No.	Date of the test	Test method
[1]	FIRES, s.r.o., Batizovce, SK	VERGOKAN, Meersbloem Melden 16, 9700 Oudenaarde, Belgium	FIRES-FR- 119-11-AUNE	02. 06. 2011	DIN 4102 – 12:1998-11

3.2 TEST RESULTS

Test report No. /Test method	Specimen No.	Cables	Track No.	Time to first failure / interruption of conductor
[1] DIN 4102-12	S1	cable (N)HXH-J E30 4x50 RM - Prysmian	X2-J	91 minutes
	S2	cable (N)HXH-J E30 4x50 RM - Prysmian	X2-J	91 minutes
	S3	cable (N)HXH-J E30 4x1,5 RE - Prysmian	X2-J	31 minutes
	S4	cable (N)HXH-J E30 4x1,5 RE - Prysmian	X2-J	39 minutes
	S5	cable (N)HXCH E30 4x50 RM/25 - Prysmian	X2-K	83 minutes
	S6	cable (N)HXCH E30 4x50 RM/25 - Prysmian	X2-K	93 minutes
	S7	cable (N)HXCH E30 4x1,5 RE/1,5 - Prysmian	X2-K	39 minutes
	S8	cable (N)HXCH E30 4x1,5 RE/1,5 - Prysmian	X2-K	93 minutes no failure / interruption



Test report No. /Test method	Specimen No.	Cables	Track No.	Time to first failure / interruption of conductor
[1] DIN 4102-12	S9	cable (N)HXHX-J E90 4x50 RM - Prysmian	X2-L	93 minutes no failure / interruption
	S10	cable (N)HXHX-J E90 4x50 RM - Prysmian	X2-L	93 minutes no failure / interruption
	S11	cable (N)HXHX-J E90 4x1,5 RE - Prysmian	X2-L	93 minutes no failure / interruption
	S12	cable (N)HXHX-J E90 4x1,5 RE - Prysmian	X2-L	93 minutes no failure / interruption
	S13	cable (N)HXCHX E90 4x50 RM/25 - Prysmian	Y2-M	93 minutes no failure / interruption
	S14	cable (N)HXCHX E90 4x50 RM/25 - Prysmian	Y2-M	93 minutes no failure / interruption
	S15	cable (N)HXCHX E90 4x2,5 RE/2,5 - Prysmian	Y2-M	93 minutes no failure / interruption
	S16	cable (N)HXCHX E90 4x2,5 RE/2,5 - Prysmian	Y2-M	93 minutes no failure / interruption
	S17	cable (N)HXH FE180 E90 4x50 RM - Prakab	Y2-N	93 minutes no failure / interruption
	S18	cable (N)HXH FE180 E90 4x50 RM - Prakab	Y2-N	76 minutes
	S19	cable (N)HXH FE180 E90 4x1,5 RE - Prakab	Y2-N	93 minutes no failure / interruption
	S20	cable (N)HXH FE180 E90 4x1,5 RE - Prakab	Y2-N	93 minutes no failure / interruption
	S21	cable (N)HXCH FE180 E30 4x50 RM/25 - Prakab	Z2-O	79 minutes
	S22	cable (N)HXCH FE180 E30 4x50 RM/25 - Prakab	Z2-O	93 minutes no failure / interruption
	S23	cable (N)HXCH FE180 E30 4x1,5 RE/1,5 - Prakab	Z2-O	88 minutes
	S24	cable (N)HXCH FE180 E30 4x1,5 RE/1,5 - Prakab	Z2-O	93 minutes no failure / interruption
	S25	cable (N)HXH FE180 E30 4x50 RM - Prakab	Z2-P	86 minutes
	S26	cable (N)HXH FE180 E30 4x50 RM - Prakab	Z2-P	93 minutes no failure / interruption
	S27	cable (N)HXH FE180 E30 4x1,5 RE - Prakab	Z2-P	93 minutes no failure / interruption
	S28	cable (N)HXH FE180 E30 4x1,5 RE - Prakab	Z2-P	93 minutes no failure / interruption
	S29	cable (N)HXCH FE180 E90 4x50 RM/25 - Prakab	Z2-Q	73 minutes
	S30	cable (N)HXCH FE180 E90 4x50 RM/25 - Prakab	Z2-Q	93 minutes
	S31	cable (N)HXCH FE180 E90 4x1,5 RE/1,5 - Prakab	Z2-Q	83 minutes
	S32	cable (N)HXCH FE180 E90 4x1,5 RE/1,5 - Prakab	Z2-Q	93 minutes no failure / interruption
	S52	cable JE-H(St)H E30 2x2x0,8 – Prysmian	X2-J	93 minutes no failure / interruption
	S53	cable JE-H(St)H E30 2x2x0,8 - Prysmian	X2-K	65 minutes
	S54	cable JE-H(St)H FE180 E90 2x2x0,8 – Prakab	Y2-N	66 minutes
	S55	cable JE-H(St)H FE180 E90 2x2x0,8 - Prakab	Z2-Q	56 minutes

[1] The fire test was discontinued in 94th minute at the request of test sponsor.

Specimens S1 – S32 were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.
Specimens S52 – S55 were tested by one-phase voltage supply 1 x 110V with LED diodes 3V /0,03W.
Circuit breakers with rating 3 A and performance characteristics B(gL) were used.



4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 CLASSIFICATION ACCORDING TO ZP-27/2008

The element, cable bearing system VERGOKAN – cable trays with accessories (consoles, brackets, screws etc.) with power and communication halogen free cables PRYSMIAN and PRAKAB with circuit integrity maintenance in fire is classified according to the following combinations of performance parameters and classes as appropriate.

Cables PRYSMIAN used by the test are classified as follows:

Cable	Type of tested cable, single cross-sections and number of conductors	Arrangement	Classification for type of tested cable (by cross-sections and number of conductors)	Classification for cable
(N)HXH E30	(N)HXH-J E30 4x1,5 RE	In cable trays KBSI60.400.100. Ceiling consoles HDHSMU50.1000 wits brackets HDWKM400. Loading 20 kg.m ⁻¹ . Consoles in spacing of 1500 mm. Non-standard track X2-J.	P 30-R	n x ≥ 1,5 mm ² n ≥ 2 P 30-R
	(N)HXH-J E30 4x50 RM		P 90-R	
JE-H(St)H E30	JE-H(St)H E30 2x2x0,8	Non-standard track X2-J and X2-K.	P 60-R	n x 2 x ≥ 0,8 mm n ≥ 2 P 60-R
(N)HXCH E30	(N)HXCH E30 4x1,5 RE/1,5	In cable trays KBSI60.400.100. Ceiling consoles HDHSMU50.1000 wits brackets HDWKM400. Loading 20 kg.m ⁻¹ . Consoles in spacing of 1500 mm. Non-standard track X2-K.	P 30-R	n x ≥ 1,5/1,5 mm ² n ≥ 2 P 30-R
	(N)HXCH E30 4x50 RM/25		P 60-R	
(N)HXHX E90	(N)HXHX-J E90 4x1,5 RE	In cable trays KBSI60.400.100. Ceiling consoles HDHSMU50.1000 wits brackets HDWKM400. Loading 20 kg.m ⁻¹ . Consoles in spacing of 1500 mm. Non-standard track X2-L.	P 90-R	n x ≥ 1,5 mm ² n ≥ 2 P 90-R
	(N)HXHX-J E90 4x50 RM		P 90-R	
(N)HXCHX E90	(N)HXCHX E90 4x2,5 RE/2,5	In cable trays KBSI60.400.100. Ceiling consoles HDHSMU50.1000 wits brackets HDWKM400. Loading 20 kg.m ⁻¹ . Consoles in spacing of 1500 mm. Non-standard track Y2-M.	P 90-R	n x ≥ 2,5/2,5 mm ² n ≥ 2 P 90-R
	(N)HXCHX E90 4x50 RM/25		P 90-R	



Cables PRAKAB used by the test are classified as follows:

Cable	Type of tested cable, single cross-sections and number of conductors	Arrangement	Classification for type of tested cable (by cross-sections and number of conductors)	Classification for cable
(N)HXH FE180 E90	(N)HXH FE180 E90 4x1,5 RE	In cable trays KBSI60.400.100. Ceiling consoles HDHSMU50.1000 wits brackets HDWKM400. Loading 20 kg.m ⁻¹ . Consoles in spacing of 1500 mm. Non-standard track Y2-N.	P 90-R	n x ≥ 1,5 mm ² n ≥ 2 P 60-R
	(N)HXH FE180 E90 4x50 RM		P 60-R	
JE-H(St)H FE180 E90	JE-H(St)H FE180 E90 2x2x0,8	Non-standard track Y2-N and Z2-Q.	P 30-R	n x 2 x ≥ 0,8 mm n ≥ 2 P 30-R
(N)HXCH FE180 E30	(N)HXCH FE180 E30 4x1,5 RE/1,5	In cable trays KBSI60.400.100. Ceiling consoles HDHSMU50.1000 wits brackets HDWKM400. Loading 20 kg.m ⁻¹ . Consoles in spacing of 1500 mm. Non-standard track Z2-O.	P 60-R	n x ≥ 1,5/1,5 mm ² n ≥ 2 P 60-R
	(N)HXCH FE180 E30 4x50 RM/25		P 60-R	
(N)HXH FE180 E30	(N)HXH FE180 E30 4x1,5 RE	In cable trays KBSI60.400.100. Ceiling consoles HDHSMU50.1000 wits brackets HDWKM400. Loading 20 kg.m ⁻¹ . Consoles in spacing of 1500 mm. Non-standard track Z2-P.	P 90-R	n x ≥ 1,5 mm ² n ≥ 2 P 60-R
	(N)HXH FE180 E30 4x50 RM		P 60-R	
(N)HXCH FE180 E90	(N)HXCH FE180 E90 4x1,5 RE/1,5	In cable trays KBSI60.400.100. Ceiling consoles HDHSMU50.1000 wits brackets HDWKM400. Loading 20 kg.m ⁻¹ . Consoles in spacing of 1500 mm. Non-standard track Y2-M.	P 60-R	n x ≥ 1,5/1,5 mm ² n ≥ 2 P 60-R
	(N)HXCH FE180 E90 4x50 RM/25		P 60-R	

The element, cable bearing system VERGOKAN – cable trays with accessories (consoles, brackets, screws etc.) with power and communication halogen free cables PRYSMIAN and PRAKAB with circuit integrity maintenance in fire are classified to classes according to achieved test results of tested cables at tracks. Other classification is not allowed.

4.2 FIELD OF APPLICATION

This classification is valid for the following end use applications:

- test results are applicable only for tested bearing systems VERGOKAN with cables PRYSMIAN and PRAKAB;
- throughout the period during which circuit integrity is to be maintained, neighbouring building components shall not have a negative effect on circuit integrity;
- although testing is only carried out on cables arranged horizontally, test results also apply to cables arranged either diagonally or vertically (e.g. risers), as long as the cable system is supported in transitional areas (i.e. where it switches from a horizontal to a vertical arrangement) in such a manner that the cables will not slip or kink at corners;
- results gained during tests of cable bearing system exposed to higher temperature are valid also for the cable trays exposed to lower temperature;
- if a set of at least two pieces of four-conductor cable with the smallest allowed nominal cross-section and two pieces of four-conductor cable with nominal cross-section of 50 mm² or larger is tested and the cables with the smallest and the largest section achieve required function in fire classification, the test result is valid for all cross-sections of cable of particular construction type and particular ways of installation;



- if the limit conductor cross-section of tested set of cables differs from above stated, the test result is valid only for such defined range of cable cross-sections of particular cable type and way of installation;
- if only cables with the smallest or largest section achieve the required function in fire classification, the test results are valid only for the particular section and way of installation;
- if minimal two pieces of communication cables with the smallest allowed number of conductors, pairs and diameters (cross-sections) are tested, the test results are valid for all diameters (cross-sections), pairs, number of conductors of cable of particular construction type and particular ways of installation;
- if cables with larger number of conductors or pairs than the smallest allowed number are tested, the test results are valid for all construction types of cable with the same or larger number of conductors, eventually pairs of particular construction type of cable and particular ways of installation;
- if the widest considered cable tray or cable ladder is tested, the test results are valid for all narrower cable trays or cable ladders of the same construction;
- if the standard support construction acc. to ZP27/2008 is used for testing, test results also apply to other types of tested support construction of other producers;
- test results of function in fire test of cables tested at standard supporting construction are also applicable for cables of other producers tested at standard supporting construction;
- test results of cables at ladders or in trays attached at ceiling are applicable also for cables placed in bearing system fixed to wall;
- **test result is applicable to welded head plate to steel U-shaped ceiling profiles;**
- **heavy joined steel brackets WKM... shall be fixed to steel U-shaped ceiling profiles HSMU from one or from two sides, providing the maximum loading of U-shaped ceiling profiles is not more than during the fire test and only if sufficient type of fixation of the head plates to ceiling is provided;**
- **use the new type of spacer TSU50 instead of spacer HDTSU50;**
- **change the construction of tested console (base of console) type HDHSMU in accordance with drawings in annex.**

5. LIMITATIONS

Load-bearing construction elements for fixing of cable systems must be proved for at least the same fire resistance compare to classified function in fire of cable system.

The construction contractor is solely responsible for proper preparation.

This classification document does not represent type approval or certification of the product.

The classification is valid until 14. 06. 2021 provided that the product, field of application and standards and regulations are not changed.


Approved:


Ing. Štefan Rástocký
leader of the testing laboratory



Signed:

Miroslav Hudák
technician of the testing laboratory










Type	Binnenmaat breedte :	Maat B		
		MD 0.8	MD 1.0	MD 1.25
KBSI 60*75	73	74.6	75	75.5
KBSI 60*100	98	99.6	100	100.5
KBSI 60*150	148	149.6	150	150.5
KBSI 60*200	198	199.6	200	200.5
KBSI 60*250	248	249.6	250	250.5
KBSI 60*300	298	299.6	300	300.5
KBSI 60*350	348	349.6	350	350.5
KBSI 60*400	398	399.6	400	400.5
KBSI 60*500	498	499.6	500	500.5
KBSI 60*600	598	599.6	600	600.5

[illegible]









[illegible]


1	A	Toevoegen van gaten d10 (zonder WH)	Number	Edition	Description of the modification	By	SC
					Date		
<div> <div>VERGOKAN</div> <div> Meersloem Melden 16 9700 Oudenaarde </div> <div> Tel: 055/3183 35 Fax: 055/3143 88 </div> </div>			Scale: 1 : 2		Adapt drawing exclusively with CAD		
			DRAWING NUMBER 46059		FORM A4		2 p.





NOT FOR PRODUCTION







Technical drawing of a heavy joined bracket showing various views and dimensions. The drawing includes a top view, a side view, and a cross-section view. Dimensions are given in millimeters (mm). The top view shows a bracket with a width (W) and a height (H). The side view shows a bracket with a width (W) and a height (H). The cross-section view shows a bracket with a width (W) and a height (H). The drawing is labeled '000-CWK 100' and '000-KPW 300'.