

## FUNCTION IN FIRE EXPERT JUDGEMENT REPORT WITH CLASSIFICATION FIRES-JR-038-11-NURE Issue 2

Cable bearing system VERGOKAN with cables PRYSMIAN and PRAKAB



*This is an electronic version of a classification report which was made as a copy of classification report officially issued in a paper form. The electronic version of a classification report shall be used only for informative purpose. Any information listed in this classification report is the property of the sponsor and shall not be used or published without written permission. Contents of this file may only be modified by the editor i.e. FIRES, s.r.o., Batizovce. Sponsor is allowed to publish this classification report in parts only with written permission of the editor.*

# FUNCTION IN FIRE EXPERT JUDGEMENT REPORT WITH CLASSIFICATION

## FIRES-JR-038-11-NURE Issue 2

**Name of the product:** Cable bearing system VERGOKAN with cables PRYSMIAN and PRAKAB

**Sponsor:** VERGOKAN  
Meersbloem Melden 16  
9700 Oudenaarde  
Belgium

**Prepared by:** FIRES, s.r.o.  
Approved Body No. SK01  
Osloboditeľov 282  
059 35 Batizovce  
Slovak Republic

**Task No.:** PR-11-0173  
**Date of issue:** 14. 12. 2011 (06. 07. 2011)

**Reports:** 3  
**Copy No.:** 2

**Distribution list:**

Copy No. 1 FIRES, s.r.o., Osloboditeľov 282, 059 35 Batizovce, Slovak Republic  
(electronic version)  
Copy No. 2 VERGOKAN, Meersbloem Melden 16, 9700 Oudenaarde, Belgium  
(electronic version)  
Copy No. 3 VERGOKAN, Meersbloem Melden 16, 9700 Oudenaarde, Belgium

This expert judgement report consists of 8 pages and 6 annexes and may only be used or reproduced in its entirety.



## 1. INTRODUCTION

This expert judgement report with classification defines the function in fire classification assigned to element: cable bearing system VERGOKAN with cables PRYSMIAN and PRAKAB in accordance with the classes given in STN 92 0205: 2010, ZP-27/2008 PAVUS and DIN 4102 – 12: 1998-11.

This expert judgement report defines field of application which is outside the field of direct application according test standard or outside the field of extended application according to relevant extended application standard. This expert judgement expresses the opinion of the FIRES and is based on the experience or internal rules of FIRES.

This expert judgement in 2<sup>nd</sup> issue of Fire resistance expert judgement report with classification No. FIRES-JR-038-11-NURE, issue by FIRES, s.r.o., Batizovce on 06. 07. 2011, into which the change of product dimensions in clauses 2.2., 4.1., 4.2., 4.3. of this document.

## 2. DETAILS OF CLASSIFIED PRODUCT

### 2.1 GENERAL

The product, cable bearing system VERGOKAN, is defined as a cable bearing system for power and communication halogen free cables with circuit integrity maintenance

### 2.2 PRODUCT DESCRIPTION

Cable bearing system is made of steel cable trays with interlocking system KBSI (60 x 400 x 1,0) mm fixed to heavy joined steel brackets WKM 400 which are fixed to steel U-shaped ceiling profiles HSMU (50 x 50 x 1000) mm.

Ceiling profiles are fixed to the ceiling in maximum span of 1500 mm.

Maximum loading of tray is 20 kg.m<sup>-1</sup>.

Details of materials, used screws and type of fixation are shown in details in drawings.

Cables used during the test:

#### **PRYSMIAN cables**

- cable (N)HXH-J E30 4x50 RM (2x);
- cable (N)HXH-J E30 4x1,5 RE (2x);
- cable (N)HXCH E30 4x50 RM/25 (2x);
- cable (N)HXCH E30 4x1,5 RE/1,5 (2x);
- cable (N)HXHX-J E90 4x50 RM (2x);
- cable (N)HXHX-J E90 4x1,5 RE (2x);
- cable (N)HXCHX E90 4x50 RM/25 (2x);
- cable (N)HXCHX E90 4x2,5 RE/2,5 (2x);
- cable JE-H(St)H E30 2x2x0,8 (2x).

#### **PRAKAB cables**

- cable (N)HXH FE180 E90 4x50 RM (2x);
- cable (N)HXH FE180 E90 4x1,5 RE (2x);
- cable (N)HXCH FE180 E30 4x50 RM/25 (2x);
- cable (N)HXCH FE180 E30 4x1,5 RE/1,5 (2x);
- cable (N)HXH FE180 E30 4x50 RM (2x);
- cable (N)HXH FE180 E30 4x1,5 RE (2x);
- cable (N)HXCH FE180 E90 4x50 RM/25(2x);
- cable (N)HXCH FE180 E90 4x1,5 RE/1,5 (2x);
- cable JE-H(St)H FE180 E90 2x2x0,8 (2x).

The length of supporting constructions and cables was 5,5 m, 4 m from that was exposed to fire. Power and communication cables were fixed to the steel sheet bearing systems in the points of allowed bending radius by steel clamps according to the cable diameter.




3. TEST REPORTS AND EXTENDED APPLICATION REPORTS IN SUPPORT OF CLASSIFICATION

3.1 TEST REPORTS AND EXTENDED APPLICATION REPORTS

No.	Name of laboratory	Name of sponsor	Test report No.	Date of the test	Test method
[1]	FIRES, s.r.o., Batizovce, SK	VERGOKAN, Meersbloem Melden 16, 9700 Oudenaarde, Belgium	FIRES-FR- 119-11-AUNE	02. 06. 2011	DIN 4102 – 12:1998-11

3.2 LAYOUT OF THE SUPPORTING CONSTRUCTION DURING THE COURSE OF THE TEST





### 3.3 TEST RESULTS

#### Power cables

Specimen No.	Cables - Manufacturer	Stretch/ support	Time to first failure / interruption of conductor
1	cable (N)HXH-J E30 4x50 RM - Prysmian	X2 - J / tray KBSI	91 minutes
2	cable (N)HXH-J E30 4x50 RM - Prysmian		91 minutes
3	cable (N)HXH-J E30 4x1,5 RE - Prysmian		31 minutes
4	cable (N)HXH-J E30 4x1,5 RE - Prysmian		39 minutes
5	cable (N)HXCH E30 4x50 RM/25 - Prysmian	X2 - K / tray KBSI	83 minutes
6	cable (N)HXCH E30 4x50 RM/25 - Prysmian		93 minutes
7	cable (N)HXCH E30 4x1,5 RE/1,5 - Prysmian		39 minutes
8	cable (N)HXCH E30 4x1,5 RE/1,5 - Prysmian		93 minutes no failure / interruption
9	cable (N)HXHX-J E90 4x50 RM - Prysmian	X2 - L / tray KBSI	93 minutes no failure / interruption
10	cable (N)HXHX-J E90 4x50 RM - Prysmian		93 minutes no failure / interruption
11	cable (N)HXHX-J E90 4x1,5 RE - Prysmian		93 minutes no failure / interruption
12	cable (N)HXHX-J E90 4x1,5 RE - Prysmian		93 minutes no failure / interruption
13	cable (N)HXCHX E90 4x50 RM/25 - Prysmian	Y2 - M / tray KBSI	93 minutes no failure / interruption
14	cable (N)HXCHX E90 4x50 RM/25 - Prysmian		93 minutes no failure / interruption
15	cable (N)HXCHX E90 4x2,5 RE/2,5 - Prysmian		93 minutes no failure / interruption
16	cable (N)HXCHX E90 4x2,5 RE/2,5 - Prysmian		93 minutes no failure / interruption
17	cable (N)HXH FE180 E90 4x50 RM - Prakab	Y2 - N / tray KBSI	93 minutes no failure / interruption
18	cable (N)HXH FE180 E90 4x50 RM - Prakab		76 minutes
19	cable (N)HXH FE180 E90 4x1,5 RE - Prakab		93 minutes no failure / interruption
20	cable (N)HXH FE180 E90 4x1,5 RE - Prakab		93 minutes no failure / interruption
21	cable (N)HXCH FE180 E30 4x50 RM/25 - Prakab	Z2 - O / tray KBSI	79 minutes
22	cable (N)HXCH FE180 E30 4x50 RM/25 - Prakab		93 minutes no failure / interruption
23	cable (N)HXCH FE180 E30 4x1,5 RE/1,5 - Prakab		88 minutes
24	cable (N)HXCH FE180 E30 4x1,5 RE/1,5 - Prakab		93 minutes no failure / interruption
25	cable (N)HXH FE180 E30 4x50 RM - Prakab	Z2 - P / tray KBSI	86 minutes
26	cable (N)HXH FE180 E30 4x50 RM - Prakab		93 minutes no failure / interruption
27	cable (N)HXH FE180 E30 4x1,5 RE - Prakab		93 minutes no failure / interruption
28	cable (N)HXH FE180 E30 4x1,5 RE - Prakab		93 minutes no failure / interruption
29	cable (N)HXCH FE180 E90 4x50 RM/25 - Prakab	Z2 - Q / tray KBSI	73 minutes
30	cable (N)HXCH FE180 E90 4x50 RM/25 - Prakab		93 minutes
31	cable (N)HXCH FE180 E90 4x1,5 RE/1,5 - Prakab		83 minutes
32	cable (N)HXCH FE180 E90 4x1,5 RE/1,5 - Prakab		93 minutes no failure / interruption

#### Communication cables

Specimen No.	Cables - Manufacturer	Stretch / support	Time to first failure / interruption of conductor
52	cable JE-H(St)H E30 2x2x0,8 – Prysmian	X2 - J / tray KBSI	93 minutes no failure / interruption
53	cable JE-H(St)H E30 2x2x0,8 - Prysmian	X2 - K / tray KBSI	65 minutes
54	cable JE-H(St)H FE180 E90 2x2x0,8 – Prakab	Y2 - N / tray KBSI	66 minutes
55	cable JE-H(St)H FE180 E90 2x2x0,8 - Prakab	Z2 - Q / tray KBSI	56 minutes



The test was terminated in 94<sup>th</sup> minute at the request of test sponsor.

Specimens S1 – S51 were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W. Specimens S52 – S55 were tested by one-phase voltage supply 1 x 110V with LED diodes 3V /0,03W. Circuit breakers with rating 3 A were used.

#### 4. CLASSIFICATION AND FIELD OF APPLICATION

##### 4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 3.2 of STN 92 0205: 2010, clause 11 of ZP-27/2008 PAVUS and clause 3.2 of DIN 4102 – 12: 1998-11.

##### 4.2 CLASSIFICATION ACCORDING TO STN 92 0205

Tray / max. span / max. loading	Cable - Manufacturer	Type of tested cable, single cross-sections and number of conductors	Classification	Range of cables (by cross-sections and number of conductors)
TRAY KBSI (60x400x1,0) / 1500 mm / 20 kg.m <sup>-1</sup>	cable (N)HXH-J E30 - Prysmian	(N)HXH-J E30 4x1,5 RE	PS 30	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXH-J E30 4x50 RM	PS 90	$n \times 50 \text{ mm}^2$ $n \geq 2$
	cable (N)HXCH E30 - Prysmian	(N)HXCH E30 4x1,5 RE/1,5	PS 30	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXCH E30 4x50 RM/25	PS 60	$n \times 50 \text{ mm}^2$ $n \geq 2$
	cable (N)HXHX-J E90 - Prysmian	(N)HXHX-J E90 4x1,5 RE	PS 90	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXHX-J E90 4x50 RM		
	cable (N)HXCHX E90 - Prysmian	(N)HXCHX E90 4x2,5 RE/2,5	PS 90	$n \times \geq 2,5 \text{ mm}^2$ $n \geq 2$
(N)HXCHX E90 4x50 RM/25				
cable JE-H(St)H E30 - Prysmian	JE-H(St)H E30 2x2x0,8	PS 60	$n \times 2 \times \geq 0,8 \text{ mm}$ ( $n \geq 2$ )	
TRAY KBSI (60x400x1,0) / 1500 mm / 20 kg.m <sup>-1</sup>	cable (N)HXH FE180 E90 - Prakab	(N)HXH FE180 E90 4x1,5 RE	PS 90	$n \times 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXH FE180 E90 4x50 RM	PS 60	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
	cable (N)HXCH FE180 E30 - Prakab	(N)HXCH FE180 E30 4x1,5 RE/1,5	PS 60	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXCH FE180 E30 4x50 RM/25		
	cable (N)HXH FE180 E30 - Prakab	(N)HXH FE180 E30 4x1,5 RE	PS 90	$n \times 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXH FE180 E30 4x50 RM	PS 60	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
	cable (N)HXCH FE180 E90 - Prakab	(N)HXCH FE180 E90 4x1,5 RE/1,5	PS 60	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
(N)HXCH FE180 E90 4x50 RM/25				
cable JE-H(St)H FE180 E90 - Prakab	JE-H(St)H FE180 E90 2x2x0,8	PS 45	$n \times 2 \times \geq 0,8 \text{ mm}$ ( $n \geq 2$ )	



#### 4.3 CLASSIFICATION ACCORDING TO ZP-27/2008 PAVUS

Tray / max. span / max. loading	Cable - Manufacturer	Type of tested cable, single cross-sections and number of conductors	Classification	Range of cables (by cross-sections and number of conductors)
TRAY KBSI (60x400x1,0) / 1500 mm / 20 kg.m <sup>-1</sup>	cable (N)HXH-J E30 - Prysmian	(N)HXH-J E30 4x1,5 RE	P 30-R	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXH-J E30 4x50 RM	P 90-R	$n \times 50 \text{ mm}^2$ $n \geq 2$
	cable (N)HXCH E30 - Prysmian	(N)HXCH E30 4x1,5 RE/1,5	P 30-R	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXCH E30 4x50 RM/25	P 60-R	$n \times 50 \text{ mm}^2$ $n \geq 2$
	cable (N)HXHX-J E90 - Prysmian	(N)HXHX-J E90 4x1,5 RE	P 90-R	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXHX-J E90 4x50 RM		
	cable (N)HXCHX E90 - Prysmian	(N)HXCHX E90 4x2,5 RE/2,5	P 90-R	$n \times \geq 2,5 \text{ mm}^2$ $n \geq 2$
		(N)HXCHX E90 4x50 RM/25		
cable JE-H(St)H E30 - Prysmian	JE-H(St)H E30 2x2x0,8	P 60-R	$n \times 2 \times \geq 0,8 \text{ mm}$ ( $n \geq 2$ )	
TRAY KBSI (60x400x1,0) / 1500 mm / 20 kg.m <sup>-1</sup>	cable (N)HXH FE180 E90 - Prakab	(N)HXH FE180 E90 4x1,5 RE	P 90-R	$n \times 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXH FE180 E90 4x50 RM	P 60-R	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
	cable (N)HXCH FE180 E30 - Prakab	(N)HXCH FE180 E30 4x1,5 RE/1,5	P 60-R	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXCH FE180 E30 4x50 RM/25		
	cable (N)HXH FE180 E30 - Prakab	(N)HXH FE180 E30 4x1,5 RE	P 90-R	$n \times 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXH FE180 E30 4x50 RM	P 60-R	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
	cable (N)HXCH FE180 E90 - Prakab	(N)HXCH FE180 E90 4x1,5 RE/1,5	P 60-R	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXCH FE180 E90 4x50 RM/25		
cable JE-H(St)H FE180 E90 - Prakab	JE-H(St)H FE180 E90 2x2x0,8	P 30-R	$n \times 2 \times \geq 0,8 \text{ mm}$ ( $n \geq 2$ )	

#### 4.4 CLASSIFICATION ACCORDING TO DIN 4102 – 12: 1998-11

Tray / max. span / max. loading	Cable - Manufacturer	Type of tested cable, single cross-sections and number of conductors	Classification	Range of cables (by cross-sections and number of conductors)
TRAY KBSI (60x400x1,0) / 1500 mm / 20 kg.m <sup>-1</sup>	cable (N)HXH-J E30 - Prysmian	(N)HXH-J E30 4x1,5 RE	E 30	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXH-J E30 4x50 RM	E 90	$n \times 50 \text{ mm}^2$ $n \geq 2$
	cable (N)HXCH E30 - Prysmian	(N)HXCH E30 4x1,5 RE/1,5	E 30	$n \times \geq 1,5 \text{ mm}^2$ $n \geq 2$
		(N)HXCH E30 4x50 RM/25	E 60	$n \times 50 \text{ mm}^2$ $n \geq 2$



Tray / max. span / max. loading	Cable - Manufacturer	Type of tested cable, single cross-sections and number of conductors	Classification	Range of cables (by cross-sections and number of conductors)
TRAY KBSI (60x400x1,0) / 1500 mm / 20 kg.m <sup>-1</sup>	cable (N)HXHX-J E90 - Prysmian	(N)HXHX-J E90 4x1,5 RE	E 90	n x ≥ 1,5 mm <sup>2</sup> n ≥ 2
		(N)HXHX-J E90 4x50 RM		
	cable (N)HXCHX E90 - Prysmian	(N)HXCHX E90 4x2,5 RE/2,5	E 90	n x ≥ 2,5 mm <sup>2</sup> n ≥ 2
		(N)HXCHX E90 4x50 RM/25		
cable JE-H(St)H E30 - Prysmian	JE-H(St)H E30 2x2x0,8	E 60	n x 2 x ≥ 0,8 mm (n ≥ 2)	
TRAY KBSI (60x400x1,0) / 1500 mm / 20 kg.m <sup>-1</sup>	cable (N)HXH FE180 E90 - Prakab	(N)HXH FE180 E90 4x1,5 RE	E 90	n x 1,5 mm <sup>2</sup> n ≥ 2
		(N)HXH FE180 E90 4x50 RM	E 60	n x ≥ 1,5 mm <sup>2</sup> n ≥ 2
	cable (N)HXCH FE180 E30 - Prakab	(N)HXCH FE180 E30 4x1,5 RE/1,5	E 60	n x ≥ 1,5 mm <sup>2</sup> n ≥ 2
		(N)HXCH FE180 E30 4x50 RM/25		
	cable (N)HXH FE180 E30 - Prakab	(N)HXH FE180 E30 4x1,5 RE	E 90	n x 1,5 mm <sup>2</sup> n ≥ 2
		(N)HXH FE180 E30 4x50 RM	E 60	n x ≥ 1,5 mm <sup>2</sup> n ≥ 2
	cable (N)HXCH FE180 E90 - Prakab	(N)HXCH FE180 E90 4x1,5 RE/1,5	E 60	n x ≥ 1,5 mm <sup>2</sup> n ≥ 2
		(N)HXCH FE180 E90 4x50 RM/25		
	cable JE-H(St)H FE180 E90 - Prakab	JE-H(St)H FE180 E90 2x2x0,8	E 30	n x 2 x ≥ 0,8 mm (n ≥ 2)

## 5. FIELD OF APPLICATION

This classification is valid for the following end use applications:

- test results are applicable only for tested bearing systems;
- maximum span of supports of cable trays is 1500 mm;
- maximum loading of tray is 20 kg.m<sup>-1</sup>;
- sufficient type of fixation of the head plates of U-shaped ceiling profiles to ceiling must be provided calculated to maximum loading of trays and span of supports;
- test results are applicable also for same supporting constructions with smaller spacing of steel U-shaped ceiling profiles and loading;
- test results are applicable also for smaller dimension range of same construction as tested;
- test results of cables in bearing systems from steel with coating services (galvanized) are applicable also for bearing systems from stainless steel or other coating services (pre-galvanized, hot-dipped);
- test results of cables in trays attached at ceiling are applicable also for cables placed in bearing system fixed to wall;
- test result is applicable to cable without connecting elements (e.g. sleeves and junction boxes);
- test result is applicable to welded head plate to steel U-shaped ceiling profiles;
- heavy joined steel brackets WKM... shall be fixed to steel U-shaped ceiling profiles HSMU from one or from two sides, providing the maximum loading of U-shaped ceiling profiles is not more than during the fire test and only if sufficient type of fixation of the head plates to ceiling is provided.





## 6. LIMITATIONS

Load-bearing construction elements for fixing of cable systems must be proved for at least the same fire resistance compare to classified function in fire of cable system.

This classification document does not represent type approval or certification of the product.

The classification is valid until 06. 07. 2016 provided that the product, field of application and standards and regulations are not changed.


Approved:

Ing. Štefan Rástocký  
head of the testing laboratory



Signed:

Bc. Dávid Šubert  
technician of the testing laboratory



Autorizovaná osoba  
MVRR SR SK01  
Approved Body No. SK01

Notifikovaná osoba č. 1396  
Notified Body No. 1396

Člen EGOLF  
EGOLF Member

Akreditovaný  
certifikačný orgán  
Accredited  
Product Certification Body

Akreditovaný inšpekčný orgán  
Accredited Inspection Body

Akreditované  
skúšobné laboratórium  
Accredited Testing Laboratory

preukazovanie zhody  
stavebných výrobkov  
conformity attestation  
of construction products

inšpekcie  
vnútropodnikovej kontroly  
inspection  
of factory production control

skúšky a klasifikácia  
požiarnej odolnosti,  
reakcie na oheň,  
mechanicko-fyzikálnych  
vlastností  
testing and classification of  
fire resistance, reaction to fire,  
mechanical and physical  
properties

teoretické hodnotenie  
požiarnej odolnosti výrobkov  
calculations of fire resistance

**FIRES, s.r.o.**  
Osloboditeľov 282  
059 35 Batizovce  
Slovakia  
tel.: +421/52/775 22 98  
fax: +421/52/788 14 12

IČO: 31701043  
IČ DPH: SK2020517059

Ludová banka, a.s.  
Poprad  
č.ú.:  
SK94 3100 0000 0043 1003 7608

S.r.o. zapísaná v Obchodnom registri  
Okresného súdu v Prešove, vložka  
č. 2093/P, oddiel: Sro.

www.fires.sk

20 JAN. 2016



**VERGOKAN**

Meersbloem Melden 16  
Oudenaarde 9700  
Belgium

**YOUR REF.**

**RESPONSIBLE**

**OUR REF.**

**BATIZOVCE**

Šubert

Su\_01\_12\_2015

01. 12. 2015

**Subject: Confirmation**

This confirmation allows to:

- use the new type of spacer TSU50 instead of spacer HDTSU50,
- change the construction of tested console (base of console) type HDHSMU in accordance with drawings, which are part of this confirmation,

provided that, rest parameters are without changes.

This confirmation is valid only with appropriate classification report:

FIRES-JR-037-11-NURD/E  
FIRES-JR-038-11-NURD/E  
FIRES-JR-051-11-NURD/E  
FIRES-JR-052-11-NURD/E  
FIRES-JR-061-11-NURE  
FIRES-JR-062-11-NURE

The construction contractor is solely responsible for proper preparation.

Best regards Bc. Dávid Šubert  
technician of testing laboratory



FIRES 204/F-30/11/2015

Autorizovaná osoba  
MVRR SR SK01  
Approved Body No. SK01

Notifikovaná osoba č. 1396  
Notified Body No. 1396

Člen EGOLF  
EGOLF Member

Akreditovaný  
certifikačný orgán  
Accredited  
Product Certification Body

Akreditovaný inšpekčný orgán  
Accredited Inspection Body

Akreditované  
skúšobné laboratórium  
Accredited Testing Laboratory

preukazovanie zhody  
stavebných výrobkov  
conformity attestation  
of construction products

inšpekcie  
vnútropodnikovej kontroly  
inspection  
of factory production control

skúšky a klasifikácia  
požiarnej odolnosti,  
reakcie na oheň,  
mechanicko-fyzikálnych  
vlastností  
testing and classification of  
fire resistance, reaction to fire,  
mechanical and physical  
properties


teoretické hodnotenie  
požiarnej odolnosti výrobkov  
calculations of fire resistance

FIRES, s.r.o.  
Osloboditeľov 282  
059 35 Batizovce  
Slovakia  
tel.: +421/52/775 22 98  
fax: +421/52/788 14 12

IČO: 31701043  
IČ DPH: SK2020517059

Ludová banka, a.s.  
Poprad  
č.ú.:  
SK94 3100 0000 0043 1003 7608

S.r.o. zapísaná v Obchodnom registri  
Okresného súdu v Prešove, vložka  
č. 2093/P, oddiel: Sro.

Parts list			NOT FOR PRODUCTION	
1	45729		[ZTSU50]	TSU verzinkt
2	B 10x80 [DIN 933]		[HOB10.80]	HD Zeskantboř
3	CRO 10 [DIN 9021]		[HOCRO.10]	HD Carosserierondsel
4	M 10 [DIN 934]	[HDM10]	Zeskantmoer M10 (HD)	
item	qty	drawing	reference	description

Ref	HDTSU--	Name	Spacer HDHSMU 50	Scale	1 : 1	Date	By
Drawn	Paul Nöte	[HDTSU50]	Standard				
Date	15/06/2011	Tolerance		DRAWING NUMBER		45730	FORM
Material	1.0037 (Hot-dip)			DRAWING NUMBER		45730	A4
			I.S.O. SYMBOL	Meersbloem Meiden 16		Tel. 055/314335	3
				9700 Oudenaarde		Fax 055/314388	P
							3
							P
							3
							P
							3
							P

Autorizovaná osoba  
MVRR SR SK01  
Approved Body No. SK01

Notifikovaná osoba č. 1396  
Notified Body No. 1396

Člen EGOLF  
EGOLF Member

Akreditovaný  
certifikačný orgán  
Accredited  
Product Certification Body

Akreditovaný inšpekčný orgán  
Accredited Inspection Body

Akreditované  
skúšobné laboratórium  
Accredited Testing Laboratory

preukazovanie zhody  
stavebných výrobkov  
conformity attestation  
of construction products

inšpekcie  
vnútropodnikovej kontroly  
inspection  
of factory production control

skúšky a klasifikácia  
požiarnej odolnosti,  
reakcie na oheň,  
mechanicko-fyzikálnych  
vlastností  
testing and classification of  
fire resistance, reaction to fire,  
mechanical and physical  
properties


teoretické hodnotenie  
požiarnej odolnosti výrobkov  
calculations of fire resistance

FIRES, s.r.o.  
Osloboditeľov 282  
059 35 Batizovce  
Slovakia  
tel.: +421/52/775 22 98  
fax: +421/52/788 14 12

IČO: 31701043  
IČ DPH: SK2020517059

Ludová banka, a.s.  
Poprad  
č.ú.:  
SK94 3100 0000 0043 1003 7608

S.r.o. zapísaná v Obchodnom registri  
Okresného súdu v Prešove, vložka  
č. 2093/P, oddiel: Sro.





**Autorizovaná osoba**  
**MVRR SR SK01**  
**Approved Body No. SK01**

**Notifikovaná osoba č. 1396**  
**Notified Body No. 1396**

**Člen EGOLF**  
**EGOLF Member**

Akreditovaný  
 certifikačný orgán  
*Accredited*  
*Product Certification Body*

Akreditovaný inšpekčný orgán  
*Accredited Inspection Body*

Akreditované  
 skúšobné laboratórium  
*Accredited Testing Laboratory*

preukazovanie zhody  
 stavebných výrobkov  
*conformity attestation*  
*of construction products*

inšpekcie  
 vnútropodnikovej kontroly  
*inspection*  
*of factory production control*

skúšky a klasifikácia  
 požiarnej odolnosti,  
 reakcie na oheň,  
 mechanicko-fyzikálnych  
 vlastností  
*testing and classification of*  
*fire resistance, reaction to fire,*  
*mechanical and physical*  
*properties*

teoretické hodnotenie  
 požiarnej odolnosti výrobkov  
*calculations of fire resistance*


**FIRES, s.r.o.**  
**Osloboditeľov 282**  
**059 35 Batizovce**  
**Slovakia**  
**tel.: +421/52/775 22 98**  
**fax: +421/52/788 14 12**

**IČO: 31701043**  
**IČ DPH: SK2020517059**

**Ludová banka, a.s.**  
**Poprad**  
**č.ú.:**  
**SK94 3100 0000 0043 1003 7608**

S.r.o. zapísaná v Obchodnom registri  
 Okresného súdu v Prešove, vložka  
 č. 2093/P, oddiel: Sro.

**Tested console:**



Autorizovaná osoba  
MVRR SR SK01  
Approved Body No. SK01

Notifikovaná osoba č. 1396  
Notified Body No. 1396

Člen EGOLF  
EGOLF Member

Akreditovaný  
certifikačný orgán  
Accredited  
Product Certification Body

Akreditovaný inšpekčný orgán  
Accredited Inspection Body

Akreditované  
skúšobné laboratórium  
Accredited Testing Laboratory

preukazovanie zhody  
stavebných výrobkov  
conformity attestation  
of construction products

inšpekcie  
vnútro podnikovej kontroly  
inspection  
of factory production control

skúšky a klasifikácia  
požiarnej odolnosti,  
reakcie na oheň,  
mechanicko-fyzikálnych  
vlastností  
testing and classification of  
fire resistance, reaction to fire,  
mechanical and physical  
properties

teoretické hodnotenie  
požiarnej odolnosti výrobkov  
calculations of fire resistance


FIRES, s.r.o.  
Osloboditeľov 282  
059 35 Batizovce  
Slovakia  
tel.: +421/52/775 22 98  
fax: +421/52/788 14 12

IČO: 31701043  
IČ DPH: SK2020517059

Ludová banka, a.s.  
Poprad  
č.ú.:  
SK94 3100 0000 0043 1003 7608

S.r.o. zapísaná v Obchodnom registri  
Okresného súdu v Prešove, vložka  
č. 2093/P, oddiel: Sro.

New console:



NOT FOR PRODUCTION

1	A	viakke kopiar	11/03/2011	notrepa	By
Number   Edition   Description of the modification			Date	Date	
Scale			Adapt drawing exclusively with CAD		
1 : 2			FORM P 1		
DRAWING NUMBER			A4		
45732			MONT		

**VERGOKAN**  
Meerbloem Heiden 16  
9700 Oudenearde  
Tel. 055/314335  
Fax. 055/314388

Name  
Ceiling profile medium heavy, U shape  
[HDHSMU50.1000]

Standard  
I.S.O SYMBOL  
Tolerance  
1.0332 (D011 hot dip)



Autorizovaná osoba  
MVRR SR SK01  
Approved Body No. SK01

Notifikovaná osoba č. 1396  
Notified Body No. 1396

Člen EGOLF  
EGOLF Member

Akreditovaný  
certifikačný orgán  
Accredited  
Product Certification Body

Akreditovaný inšpekčný orgán  
Accredited Inspection Body

Akreditované  
skúšobné laboratórium  
Accredited Testing Laboratory

preukazovanie zhody  
stavebných výrobkov  
conformity attestation  
of construction products

inšpekcie  
vnútropodnikovej kontroly  
inspection  
of factory production control

skúšky a klasifikácia  
požiarnej odolnosti,  
reakcie na oheň,  
mechanicko-fyzikálnych  
vlastností  
testing and classification of  
fire resistance, reaction to fire,  
mechanical and physical  
properties

teoretické hodnotenie  
požiarnej odolnosti výrobkov  
calculations of fire resistance

FIRES, s.r.o.  
Osloboditeľov 282  
059 35 Batizovce  
Slovakia  
tel.: +421/52/775 22 98  
fax: +421/52/788 14 12

IČO: 31701043  
IČ DPH: SK2020517059

Ľudová banka, a.s.  
Poprad  
č.ú.:  
SK94 3100 0000 0043 1003 7608

S.r.o. zapísaná v Obchodnom registri  
Okresného súdu v Prešove, vložka  
č. 2093/P, oddiel: Sro.

New console:

NOT FOR PRODUCTION

No.	Description of the modification	Date	By	Scale	FORM	P. 2
1	A. Teoregion van gaten dB (zonder WFI)	11/08/2014		1 : 2	A4	2

VERGOKAN

Meerslootweg 16 Tel. 055/3183.35  
9700 Oudehaarde Fax. 055/314.388

Name Head plate type HSLE3---	I.S.O. SYMBOL
[OKPHSLE3]	Standard
Tolerance	-
Material 1.0332 (DD11 untreated)	-